

**OFFICE OF THE PRINCIPAL, UJJAIN ENGINEERING
COLLEGE, UJJAIN. (MP) – 456 010**



(Declared Autonomous by Govt. of M.P.)

Tel (O) (0734)-2511912
Fax (0734)-2511912
e-mail principal.uecu@gmail.com
Web-site www.uecu.ac.in



No./UECU/CMD/Consul/4557 /2025,

Ujjain, Dated 17/3 /2025

To,

ST. Martin's School
Shekhpur, Badnagar Distt. Ujjain

SUB : Testing Result of water sample

REF : Your letter No./ Q Dated: 06/3/2025

With reference to the subject cited above please find result of test on WATER Sample

S. No	Name of Test	Results
1	pH	7.1
2	Chloride content	90mg/lit
3	TDS	105mg/lit
4	Total Hardness	250mg/lit

Note :-Water is suitable for drinking purpose.

Tested by

Dr.A.K.Dwivedi :

Principal,
Ujjain Engineering College,
Ujjain. (MP)

IMPS ID. 507212597723 / Dated 06/03/2025 for Rs. Rs. 8,280/-

Ujjain Engineering College, Ujjain Indian Overseas Bank A/C No. : 217201 000 00 4001; IFSC Code
No. : IOBA 0002172 Office of the Principal, Ujjain Engineering College, Ujjain. (MP) – 456 010

**OFFICE OF THE PRINCIPAL, UJJAIN ENGINEERING COLLEGE,
UJJAIN. (MP) – 456 010**



(Declared Autonomous by Govt. of M.P.)

Tel (O)

(0734)-2511912

Fax

(0734)-2511912

e-mail

principal.uecu@gmail.com

Web-site

www.uecu.ac.in



No./UECU/CED/Consul/4555 /2025,

Ujjain, Dated 17/3 /2025

To,
President
St. Martin's School
Shekhpur, Badnagar,
Dist. – Ujjain (M.P.)

SUB : Third Party Inspection Regarding to Building Safety, Water and Sanitary Condition of
School Building.

REF : Your letter No:- Q/ /2024-25

DATED :- 06/03/2025

With reference to the subject cited above a team of Prof. Savita Maru visited above site on dated 13/03/2025. It is seen that the Existing Building of St. Martin's School at Shekhpura, Badnagar Dist. Ujjain (M.P.) is in Good condition in structurally and also Water Supply & Sanitary system of building is Good in condition.

Overall the Condition of School Building is Fit for running the School.

Encl.: As above.

Checked by:- Prof. Savita Maru

Savita Maru
17/3/25

[Signature]
Principal,
Ujjain Engineering College,
Ujjain. (MP)

MPTC No. / / Dated / /202__ for Rs.

Ujjain Engineering College, Ujjain Indian Overseas Bank A/C No. : 217201 000 00 4001; IFSC Code No. : IOBA 0002172